CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20181482 Address: 619 NE LONE HILL DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Thursday, May 16, 2019
Corrective Action Required:			
1 Misc	 -Make sure the sewer manhole at front lot corner is at final grade level -Lower water meter to final grade -Final grade, sod, splash blocks -Address near light source -Seal exterior -Min 2" clearance required from siding to concrete slab exposed to rain splash -Provide landing at window well -Install security strike plate at exterior doors fasten to jamb studs with 3" screws 		

Comments: