

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172503
Address: 205 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mark Harding	Failed	Thursday, May 16, 2019

Corrective Action Required:

1	Misc	Joist hangers in garage 13. Studs under LVL's. Draft stop in garage 4. Add stud in garage 1. Strap west over hangs. Hurricane straps on gables. Need 4" between trap and drain. Seal pipes between concrete and plywood. Support HVAC every 6ft. Add stud on north side 1st floor by the dryer box. stairs not installed
---	------	---

Comments: