

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183200
Address: 1706 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Partial	Friday, May 17, 2019

Partial Correction:

1	Misc	OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING AT: EAST WING SOUTH OF CORR (123) INCLUDING MBD @ E WING; FROM UNITS A128, A130, A131, 132 TO BUILDING DRAIN @ CORR 123; WEST HALF OF BUILDING NORTH OF E-W LINE DEFINED BY SOUTH WALL OF BASE UNIT A108;
---	------	--

ENSURE PRESSURE-TESTING OF PIPING SYSTEM IS PERFORMED PER IPC 312 /
IRC P2503.5.1

Comments: