CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #:	PRSUBD20184050	
Addrace.		

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

DE - Sanitary Sewer - Mandrel John DiMauro Passed Friday, May 17, 2019

Informational:

1 Misc On site with the Redford crew for the mandrel test. I verified the mandrel

was the correct size according to the city spec. I observed the mandrel pull

through both sanitary sewer lines 3-A & 3-B with no deflection.

Test Passed.

Comments: