

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20170401

Address: 3530 SW HOLLYWOOD DR, Unit:3, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mike Copeland	Failed	Friday, May 17, 2019

Corrective Action Required:

- | | | |
|---|-------------|---|
| 1 | THIRD FLOOR | 1. Putty pads on back to boxes, Check all.
2. Overdrilled 2x6 studs for plumbing.
3. Firestop line sets stair towers. Strap plates same locations.
4. Unit 303, missing nipple in panel.
5. Unit 302 missing firestop south wall.
6. Firestop tub traps.
7. Electrical conductor protection. Check all. |
|---|-------------|---|

Corrective Action Required:

- | | |
|---|-------------|
| 2 | THIRD FLOOR |
|---|-------------|

Comments: