

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20182837
Address: 450 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|--------------|----------|----------------------|
| DE - Commercial Curb Inspection | John DiMauro | Passed | Friday, May 17, 2019 |

Informational:
1 Misc

Talked with John from the contracting company on site.

AB-3 base around the curb radius had adequately placed thickness and compaction for curb placement. I informed contractor that cure and cover was required for concrete due to the nighttime temperatures.

Informational:
2 Misc

A section of the curb on the back (west) side of the building was replaced today.

Photos Attached

Comments: