

Inspection Summary

Permit #: PRSUBD20182996, Development - Subdivision
OAKVIEW STORAGE PHASE II
Address: 1410 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DE - Stabilized Subgrade	Joe Starlin	Passed	Thursday, May 16, 2019

Informational

1 4-24-19 The Portland was mixed in all roadways.

Informational

2 5-15-19 9am proof roll. The sub grade passed with corrections to a few areas. Third party inspector from Contech was on site and determined what was needed as far as corrections.

DE - Subgrade Inspection	Joe Starlin	Partial	Thursday, May 16, 2019
--------------------------	-------------	---------	---------------------------

Informational

1 5-16-19 They are laying base rock type 3 on all road surfaces and are planning for a proof roll the following week. 2:25pm All base rock has been laid.

DE - Subgrade Inspection	Joe Starlin	Partial	Thursday, May 16, 2019
--------------------------	-------------	---------	---------------------------

Informational

1 5-16-19 They are laying base rock on all road surfaces and are planning for a proof roll the following week. 2:25pm All base rock has been laid.

Comments:

