CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20183588

Address: 2614 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

Inspected On: Monday, May 20, 2019

Inspected By: Brandon Kalwei

Expiration Date:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Brandon Kalwei Temporary C of O Monday, May 20,

Codes Residential 2019

Corrective Action Required:

1 Misc -dbl 2x10 on deck over span.

-Final grade, splash blocks, sod, erosion control.

Corrective Action Required:

2 Misc