

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20183153  
Address: 3320 SW JESSIE LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                               | Inspector:     | Outcome: | Date:                 |
|-------------------------------------------|----------------|----------|-----------------------|
| <b>All Rough Inspection - Residential</b> | Brandon Kalwei | Failed   | Tuesday, May 21, 2019 |

Corrective Action Required:

|   |      |                                                                                                                                                                                                                    |
|---|------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | Misc | -properly nail corner studs in south bedroom on 1st floor<br>-properly nail NW corner wall studs in basement<br>-security blocking basement door<br>-no erosion control in front, debris and mud going into street |
|---|------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**Comments:**