



PLAN REVIEW CONDITIONS

May 22, 2019

DEATON MARK R & LISA M
4409 SE SECRETARIAT DR
LEES SUMMIT, MO 64082

Permit No: PRCOM20191295
Project Title: THE SOCIAL SALON AND SPA
Project Address: 807 SW OLDHAM PKWY, LEES SUMMIT, MO 64081
Parcel Number: 61420052100000000
Location: MANG ADDITION LOT 6A, A REPLAT OF LOTS 6, 7, 19 & 20 MANG ADDITION---LOT 6A
Type of Work: CHANGE OF TENANT
Occupancy Group: BUSINESS
Description: TENANT FINISH FOR HAIR SALON

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Pending

Fire Plan Review

Reviewed By: Joe Dir

Rejected

1. 2018 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

ACTION REQUIRED: (verified at inspection)

Numeric address (807) shall be readable from the address roadway (Oldham Parkway)

2. 2018 IFC 906.5- Conspicuous location. Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. These locations shall be along normal paths of travel, unless the fire code official determines that the hazard posed indicates the need for placement away from normal paths of travel.

ACTION REQUIRED: (verified at inspection)

Provide a minimum of one 2A-10BC fire extinguisher (5 pound) for the first floor salon/spa area and one

2A-10BC fire extinguisher (5 pound) for the basement area. Extinguishers are to be mounted on a wall or an extinguisher cabinet on a normal path of travel close to an exit.

3. 2018 IFC 1010.1.9 Door operations. Except as specifically permitted by this section, egress doors shall be readily openable from the egress side without the use of a key or special knowledge or effort.

ACTION REQUIRED: (verified at inspection)

NO keyed cylinder locks on the egress side (interior) on an exit.

4. 2018 IFC 1008.1 Illumination required. The means of egress, shall be illuminated at all times the building space served by the means of egress is occupied.

ACTION REQUIRED: Provide emergency lighting for the exterior stairways, ADA ramp and the interior stairway to the basement.

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.