

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182860
Address: 697 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Failed	Wednesday, May 22, 2019

Corrective Action Required:

1	Misc	NEC 600.3 UL LISTING OF EXTERIOR LIGHTED SIGNS / DECORATIVE ELEMENTS: IF INTERNALLY LIGHTED, MUST BE UL SHOP-LABELED AS INDICATION OF LISTING.
---	------	--

NEC 600.4 ELECTRIC SIGN MARKINGS: SIGNS AND OUTSIDE LIGHTING SYSTEMS SHALL BE SHOP-LABELED WITH LISTING, MANUFACTURER'S NAME, TRADEMARK, OR OTHER MEANS OF IDENTIFICATION; AND INPUT VOLTAGE AND CURRENT RATING.

Corrective Action Required:

2	Misc	18" VERTICAL GRAB BAR AT WOMENS' RESTROOM MOUNTED LOWER THAN 39"-41" AFF TO BOTTOM
---	------	--

Corrective Action Required:

3	Misc	ANSI 603.3 MOUNTING OF MIRRORS AT ACCESSIBLE RESTROOMS: SET BOTTOM OF VIEWING SURFACE <= 40" AFF
---	------	--

Corrective Action Required:

4	Misc	SEAL BOTTOM OF WATER CLOSETS TO FLOOR.
---	------	--

Corrective Action Required:

5	Misc	OCCUPANCY STATUS: OK TO SET UP FOR BUSINESS. STAFFING, TRAINING, FIXTURING, STOCKING OK. NO PUBLIC OR CUSTOMERS PRIOR TO APPROVAL.
---	------	--

Comments: