

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20182996  
Address: 1410 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Erosion Sediment Control (ESC) Inspection</b>	Joe Starlin	Failed	Wednesday, May 22, 2019

Informational:

1 Misc

All erosion control measures are in place properly.

Informational:

2 Misc

5-22-19 The silt fence is down on the NE corner of the site as well as areas on the west side of the site. Spoke with the GC and he said they will make corrections in the AM on 5-23-19.

**Comments:**