

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20182837  
Address: 450 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Street - Surface Course</b>	Ronald Paynter	Passed	Thursday, May 23, 2019

Informational:

1	Misc	J&J Asphalt laid 1 1/2 inches of APWA-5 asphalt for the surface of the parking lot. The area between the ADA ramps is less than 2 percent cross slope.
---	------	--

Informational:

2	Misc	Moaz Construction patched the hole in the handicapped parking spot with virgin surface mix 1/2". Was told they would be using 2-01 asphalt mix.
---	------	---

**Comments:**