

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20183167
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Erosion Sediment Control (ESC) Inspection	Steve Robbins	Partial	Thursday, May 23, 2019

Informational:
1 Misc 5-23-19 Silt fence is down in random spots of the job site. I called Jonathan Myers the project manager at 8:45am about the erosion control, he said he would address the problem areas.

Comments: