

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20170812  
Address: 1622 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Brandon Kalwei	Failed	Thursday, May 23, 2019

Corrective Action Required:

- |   |      |   |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none"><li>• Missing 3 joist hangers at deck</li><li>• Self closing hinges at garage entry not operating properly</li><li>• Bag on smoke in furnace room</li><li>• Lockouts for oven and range</li><li>• Provide as graded plot plan</li></ul> |
|---|------|---|

**Comments:**