CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182860

Address: 697 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes John Borns Partial Friday, May 24, 2019

Commercial

Corrective Action Required:

1 Misc NEC 600.3 UL LISTING OF EXTERIOR LIGHTED SIGNS / DECORATIVE ELEMENTS:

IF INTERNALLY LIGHTED, MUST BE UL SHOP-LABELED AS INDICATION OF

LISTING.

NEC 600.4 ELECTRIC SIGN MARKINGS: SIGNS AND OUTSIDE LIGHTING SYSTEMS

SHALL BE SHOP-LABELED WITH LISTING, MANUFACTURER'S NAME,

TRADEMARK, OR OTHER MEANS OF IDENTIFICATION; AND INPUT VOLTAGE

AND CURRENT RATING.

Corrective Action Required:

5 Misc OCCUPANCY STATUS: OK TO SET UP FOR BUSINESS. STAFFING, TRAINING,

FIXTURING, STOCKING OK. NO PUBLIC OR CUSTOMERS PRIOR TO APPROVAL.

Comments: