

Inspection Summary

Permit #: PRSITE20183647, Development - Site

PARAGON STAR

Address: 1401 NW VIEW HIGH DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DE - Site Visit	Steve Robbins	Partial	Friday, May 24, 2019

Informational

- 1 The crossing in the Little Blue has been removed. All equipment and debris has also been removed from the floodway. The contractors will not be working in the floodway and when they are near the floodway it will be staked and marked so it is clear as to where they need to be. As of now this is putting an end to the Stop Work Order. Steve Robbins 04/08/2019 9:47 AM

Informational

- 2 This project cannot have anymore work done except finish the storm line on 300 and toe-wall. John Jackson will be checking on this to make sure it gets wrapped up. No work until further notice.

Comments: