

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20170401
Address: 3530 SW HOLLYWOOD DR, Unit:3, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|---------------|----------|-------------------------|
| All Rough Inspection - Commercial | Mike Copeland | Partial | Wednesday, May 29, 2019 |

Partial Correction:

| | | |
|-----------------------------|--------------|--|
| 1 | THIRD FLOOR | THIRD FLOOR APPROVED |
| Corrective Action Required: | | |
| 2 | SECOND FLOOR | -DOUBLE WALLS, PUTTY PADS ON BACK TO BACK BOXES -FIRESTOP LINE SET UNIT 207 BY TUB. |

Comments: