## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

## **Temporary** Certificate of Occupancy

Permit #:	PRRES20183171		
Address:	1630 SW BLACKSTONE PL, LEES SUMMIT, MO 64082		
Inspected On:	Wednesday, May 29, 2019		
Inspected By:	Jason McRoy		
<b>Expiration Date:</b>	7/29/2019 12:00:00 AM		

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.** 

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Jason McRoy	Temporary C of O	Wednesday, May 29, 2019

Corrective Action Required:

1 Misc 1.DECK LEDGER BOARD ATTACHMENT NOT ALLOWED TO ATTACH TO CANTILEVER. DOUBLE HEADER AND DOUBLE BOTH SUPPORTING JOISTS . INSTALL JOIST HANGERS AT ALL. 2. FINAL GRADING. 3. SOD. 4. PROVIDE AS GRADED PLOT PLAN PRIOR TO SOD.