

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20180561
Address: 1510 SE KINGSPPOINT DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Fire Line Construction Inspection	Marquelle Williams	Passed	Wednesday, May 29, 2019

Informational:
1 Misc Advanced Fire and Protection crew cut into water main and installed a T for a fire line and back flow preventer according to Spec. Crew still needs to attach fire line to building and has thrust block remaining

Comments: