

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20182738  
Address: 2606 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mark Harding	Not Ready	Thursday, May 30, 2019

Corrective Action Required:

1	Misc	INSTALL EROSION CONTROL AS REQUIRED ALL INSPECTIONS DENIED UNTILL EROSION CONTROL IS IN PLACE
---	------	--

**Comments:**