

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRLD20180325  
Address: 2100 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Erosion Sediment Control (ESC) Inspection</b>	Steve Conrick	Failed	Thursday, May 30, 2019

Corrective Action Required:

1	PW-Erosion and Sediment Control	Silt fence is down in two areas and needs to be cleaned out and restaked. See pics
---	---------------------------------	--

Corrective Action Required:

2	PW-Erosion and Sediment Control	Be sure to keep SWPPP reports on site and send to the city inspector each time they are completed.
---	---------------------------------	--

**Comments:**