

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSITE20180561  
Address: 1510 SE KINGSPPOINT DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Fire Line Construction Inspection</b>	Marquelle Williams	Passed	Friday, May 31, 2019

Informational:

1 Misc

Advanced Fire and Protection crew cut into water main and installed a T for a fire line and back flow preventer according to Spec. Crew still needs to attach fire line to building and has thrust block remaining

Informational:

2 Misc

Advanced Fire Protection finished the install of the fire line from the back flow preventer to the existing fire line connected to the building. I verified the correct materials and that the install met the City of Lee's Summit specs. Photos are attached.

**Comments:**