

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191196
Address: 198 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Failed	Monday, June 03, 2019

Corrective Action Required:

1	Misc	REMOVE ABANDONED CONDUIT SECURE MC CABLE W/I 12" OF BOXES SECURE BOXES TO STRUCTURE CLOSE ALL ACTIVE BOXES
---	------	---

Comments: