

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20180561
Address: 1510 SE KINGSPPOINT DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Fire Line - Hydrostatic Test	John DiMauro	Passed	Monday, June 03, 2019

Informational:

1 Misc

Advantage Fire performed the Hydro test on the fire line.

I observed the gauge hold 205 psi for two hours.

Test Passed.

Comments: