

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20183161
Address: 3324 SW JESSIE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Marquelle Williams	Passed	Monday, June 03, 2019

Informational:
1 Misc

PRE POUR INSPECTION

At time of inspection, all forms are in place. Drive way approach is filled with clean gravel, 4" in depth and is compacted.

Informational:
2 Misc

POST POUR INSPECTION

Driveway meets all Spec. Cross slope meets ADA spec for the future sidewalk to be put in.

Comments: