

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20181667
Address: 2601 SW PRYOR RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Street - Proof Roll	John DiMauro	Partial	Tuesday, June 04, 2019

Informational:

1 Misc

Randy Spalding Excavation proof rolled the street for the Fly Ash treated subgrade that was installed two weeks ago. The crew plans to install base rock today and will call for another proof roll at a later date.

Comments: