

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20172500  
Address: 201 NW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Mark Harding	Partial	Tuesday, June 04, 2019

Corrective Action Required:

1	LOWER LEVEL	COMPLETE WALL INTO MEDIA ROOM AND SECURE ELECTRICAL. TIE ALL GROUNDS IN CEILING BOXES. SECURE ALL NM WITHIN 12" OF BOX, AND 4.5FT O.C. TERMINATE ELECT TO CEILING BOX AT CEILING OF MEDIA ROOM.
---	-------------	--

CLOSET AT REAR OF MEDIA ROOM INCOMPLETE.

Corrective Action Required:

2	FIRST FLOOR	SOFFIT IN MAIL ROOM OK. SOFFIT AT FRONT FOYER NEEDS GROUNDS TIED AND NM SECURED.  TIE GROUNDS AT CEILING BOXES ON DECK.
---	-------------	--

**Comments:**