

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20182738  
Address: 2606 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mark Harding	Not Ready	Wednesday, June 05, 2019

Corrective Action Required:

1	Misc	INSTALL EROSION CONTROL AS REQUIRED ALL INSPECTIONS DENIED UNTILL EROSION CONTROL IS IN PLACE. locked no nockbox code not ready
---	------	--

Corrective Action Required:

2	Misc	No city approved plans on site.  Provide City of Lee's Summit stamped set with permit number and address on site at time of inspection. install silt fence at rear of lot and south down hill side. -contain all trash and construction debris in front yard.  install fire stopping and complete electrical in garage, front garage walls. see list from 2505 complete on this house before recalling for inspection. 3rd not ready inspection pay assessed fees .
---	------	---

**Comments:**