

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20190564
Address: 4700 NE POCONO CIR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|--------------|----------|-------------------------|
| Electrical Service Inspection - Residential | Khanh Nguyen | Failed | Thursday, June 06, 2019 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -The grounding electrode conductor shall be continuous from service panel to ufer with no splice or the splice must be irreversible -Install a listed rebar grounding clamp. The copper conductor must not be in direct contact with dissimilar metal |
|---|------|--|

Comments: