CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183263

Address: 829 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Footing Inspection - Commercial John Borns Partial Friday, June 07, 2019

Partial Correction:

1 Misc OK TO POUR WHEN READY WALL SPREAD FOOTING AT: ON D.5 FROM D.4 TO

D.S + 4'; FOOTING STEPS AT D.K and D.L; CANTILEVERED SITE WALL FOOTING;

PERIMETER TRENCH FOOTING: LOWER LEVEL WITH UFER GROUND JUMPERS IN

PLACE AT SOUTH AND NORTH ENDS; UPPER LEVEL

Partial Correction:

2 Misc OK TO POUR WHEN READY FOOTING FOR RETAINING WALL BETWEEN BLDGS #2

& #3

Comments: