

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20190156
Address: 3336 SW JESSIE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Brandon Kalwei	Failed	Friday, June 07, 2019

Corrective Action Required:

1	Misc	-Strap needs to be above double top plate, left of garage door -Fire blocking dead space between main living and master bedroom at top plate -Nail sills per code in garage -Hook up electrical box going into suspended slab room -ok to insulate
---	------	--

Comments: