

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20190043  
Address: 1912 NE CATALINA AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:  | Inspector:   | Outcome: | Date:                 |
|--|--------------|----------|-----------------------|
| <b>Electrical Service Inspection - Residential</b> | Khanh Nguyen | Failed   | Monday, June 10, 2019 |

Corrective Action Required:

|   |      |  |
|---|------|--|
| 1 | Misc | -Flip the grounding clamp bottom half to be able to tighten connection |
|---|------|--|

**Comments:**