

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20170396  
Address: 3500 SW HOLLYWOOD DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Piping Inspection - Commercial</b>	Mike Copeland	Failed	Monday, June 10, 2019

Corrective Action Required:  
1 Misc

PRESSURE TEST APPROVED.

UNDERGROUND, UNDERSLAB FUEL GAS PIPING REQUIRES TRACER WIRE WITH THE PIPE. DO NOT COVER UNTIL THIS IS INSTALLED AND APPROVED.

**Comments:**