

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20173864
Address: 1510 SE KINGSPPOINT DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	Mike Copeland	Failed	Monday, June 10, 2019

Corrective Action Required:

1	Misc	-SUBMIT AS GRADED SURVEY FOR DETENTION BASIN -WATER METER NEEDS TO BE SET FLUSH WITH THE ELEVATION OF THE SIDEWALK -WATER METER NEEDS TO BE 14"-18" FROM THE METER WELL LID -NORTH MAN HOLE NEEDS TO BE FLUSH WITH GRADE -OBTAIN PLANNING APPROVAL
---	------	--

Comments: