

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20190984  
Address: 2240 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Water Line - Construction Inspection</b>	Marquelle Williams	Partial	Tuesday, June 11, 2019

Informational:  
1 Misc Heartland Heavy crew installed 209 LF of 6" AWWA C900 Fire Line pipe. Pipe was laid with the appropriate amount of gravel on top and bottom. Fire line was also installed with tracer wire.

**Comments:**