

DEVELOPMENT SERVICES

PLAN REVIEW CONDITIONS

June 11, 2019

PACT CONSTRUCTION SERVICES
2321 NE INDEPENDENCE AVE STE B
LEES SUMMIT, MO 64064

Permit No: PRCOM20191207
Project Title: AMERICAN SHAMAN
Project Address: 3520 SW MARKET ST, LEES SUMMIT, MO 64082
Parcel Number: 70500031400000000
Location: SUMMITCREST PLAZA LOT 1--- LOT 1
Type of Work: CHANGE OF TENANT
Occupancy Group: MERCANTILE
Description: TENANT FINISH FOR CBD SALES

*drawing is in plan review file

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Joe Dir

Approved with Conditions

1. 2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. .A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

ACTION REQUIRED:(information purposes)

If not existing add fire alarm system notification devices in the business. (horn/strobes)

Have the fire alarm system contractor provide shop drawings of any modification done to the fire alarm system.

2. 2018 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

ACTION REQUIRED:(verified at inspection)

The numeric address of 3520 shall readable from the roadway on the front and rear doors.

3. 2018 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

ACTION REQUIRED:(information purposes)

Have the fire sprinkler contractor provide shop drawings of any modification to be done to the fire sprinkler system.

4. 2018 IFC 906.2- General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

ACTION REQUIRED:(verified at inspection)

Provide a minimum of one 2A-10BC (5 pound) fire extinguisher. Fire extinguisher shall be mounted on a wall or in a extinguisher cabinet on a normal path of travel close to an exit.

6. 2018 IFC 1010.1.9 Door operations. Except as specifically permitted by this section, egress doors shall be readily openable from the egress side without the use of a key or special knowledge or effort.

ACTION REQUIRED:(verified at inspection)

No keyed locks on the egress side(interior) of an exit.

7. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:(information purposes)

Fire alarm system devices that are unhooked, relocated and or installed new will require an acceptance test prior to the final occupancy inspection. Contact the fire department to schedule testing. (816)969-1300

Building Plan Review

Reviewed By: Joe Frogge

Approved

Licensed Contractors

Reviewed By: Joe Frogge

Approved

☒ Approved to issue per the listed conditions.

☐ Do not issue per the listed conditions.

☐ Approved to construct foundation only per the listed conditions.

☐ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

Signature of Applicant

Date

Print Applicant Name

CompanyName

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

