

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191308
Address: 211 SE DOUGLAS ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Failed	Thursday, June 13, 2019

Corrective Action Required:

1	Misc	TOP OF NEW WALL TO BE FIRE-BLOCKED TO ADJACENT STRUCTURAL WALL
---	------	--

Comments: SURFACE-MOUNTED ELECTRICAL BOXES OK TO CLOSE WHEN READY.