

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183262
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Commercial	John Borns	Passed	Thursday, June 13, 2019

**Comments: BONDING AT SPA POOL: OK TO COVER WHEN READY BONDING TERMINATIONS AT WALL STEEL.
LEADS IN PLACE FOR LIGHT AND FOR ANCHORS FOR POOL LADDER AND OTHER POOL ACCESSORIES.**