CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183263

Address: 829 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Underslab Plumbing Inspection John Borns Partial Thursday, June 13,

- Commercial 2019

Partial Correction:

1 Misc OK TO COVER WHEN READY **UNDER-SLAB PVC SANITARY DRAIN, WASTE, &**

VENT PIPING AT: UPPER LEVEL

ENSURE PRESSURE-TESTING OF PIPING SYSTEM IS PERFORMED PER IPC 312 /

IRC P2503.5.1

Comments: