

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20170401
Address: 3530 SW HOLLYWOOD DR, Unit:3, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mike Copeland	Failed	Thursday, June 13, 2019

Partial Correction:

1	THIRD FLOOR	THIRD FLOOR APPROVED
---	-------------	----------------------

Partial Correction:

2	SECOND FLOOR	2ND FLOOR APPROVED TO COVER
---	--------------	-----------------------------

Partial Correction:

3	FIRST FLOOR	-APPROVED TO COVER
---	-------------	--------------------

Corrective Action Required:

4	Misc	2 loctions for draft stop, mid-point north south, west exterior wall. South end between unit and hallway
---	------	---

Comments: