

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20183167
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Stabilized Subgrade	Steve Robbins	Partial	Friday, June 14, 2019

Informational:
1 Misc 6-14-19 8:20am Rain is moving in at 8:45am We proof rolled along the south side of the site. Half passed and half failed. We rolled at the SW corner of the site and had some failures. It will need another proof roll.

Comments: