

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20183263  
Address: 829 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection</b> <b>- Commercial</b>	John Borns	Partial	Friday, June 14, 2019

Partial Correction:

1	Misc	OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING AT: UPPER LEVEL
---	------	--

ENSURE PRESSURE-TESTING OF PIPING SYSTEM IS PERFORMED PER IPC 312 / IRC P2503.5.1

Partial Correction:

2	Misc	NO ISSUES FOUND WITH <b>UNDER-SLAB RADON PIPING NETWORK AT UPPER LEVEL</b>
---	------	--

**Comments:**