



PLANS REVIEW CONDITIONS

Permit No:	PRCOM20191554	Date:	June 14, 2019
Project Title:	Home Depot Fire Alarm	Applicant:	
Location:	651 SE Oldham Pkwy Lee's Summit, MO 64081	J V PROTECTION	
Type of Work:		5231 NE ANTIOCH RD STE 200	
Occupancy Group:		KANSAS CITY, MO 64119-	
Description:	Replacement of Fire Alarm System	Primary: (816) 372-1810	
Construction Type:			
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Action Required)

Call 969-1300 to schedule a test. Test required prior to system being put into service.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.