


June 5, 2019



City of Lee's Summit  
220 SE Green Street  
Lee's Summit, Missouri 64063

Attn: Building Inspections  
Re: McFarland Custom Homes, Eagle Creek, Lot 681, 2621 SW River Trail Road,  
Lee's Summit, Missouri, Permit No. 2019-0288; suspended garage slab inspection

To whom it may concern:

An inspection was conducted on Wednesday, June 05, 2019 regarding the above referenced. For reference purposes, the house faces west. The ½" steel reinforcing was in place 12" o.c.b.w. along with metal deck forms. The steel I-beam was in place side to side under the slab and under the metal decking. The second mats of ½" steel rebars 12" o.c. front to back was in place over the steel I-beam. There are (2) steel posts in place under the steel I-beam. Permission was given to MD Concrete to place the concrete into the suspended garage slab forms. If you have any questions, please contact me at my office.

Sincerely,  
Logan & Associates, Inc.

Charles R. Logan, P.E.  
President

cc: McFarland Custom Homes

