

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20183936
Address: 1450 SE BROADWAY DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Storm - Sewer Construction Inspection	Marquelle Williams	Partial	Friday, June 14, 2019

Informational:

1 Misc

Crew installed approx 200 LF of the HDPE storm line on site. The crew also stubbed into the existing field inlet structure. Crew is going to pour collar at later date. Photos are attached.

Comments: