

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20182996  
Address: 1410 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Street - Base Lift</b>	Joe Starlin	Partial	Saturday, June 15, 2019

Informational:

1 Misc

6-15-19 72 degrees cloudy. O'Donnell Way Construction are laying the asphalt base. The temperature out of the trucks has been around 270 degrees and out of the paver about the same. Geotech is doing the testing. Superior is also on site for testing. They finished base at 11:30am. I have collected all type 5 asphalt tickets.

**Comments:**