

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20181667
Address: 2601 SW PRYOR RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Public Curb Inspection	John DiMauro	Partial	Monday, June 17, 2019

Informational:

1 Misc

Ray Cochran Concrete installed a portion of the public curb. I verified the concrete mix type was KCMMB and that the install met the City of LS standard specs. Photos are attached.

Informational:

2 Misc

Ray Cochran Concrete crew is on site installing the public road curbs. KC Testing Lab is also on site testing the slump, air and strength. They will provide me with the results.

I will return for further inspection later today.

Comments: