



PLAN REVIEW CONDITIONS

June 17, 2019

MOODY NOLAN INC
300 SPRUCE ST
COLUMBUS, OH 43215-

Permit No: PRCOM20191480
Project Title: LEE'S SUMMIT MEDICAL CENTER PHARMACY RENOVATIONS
Project Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063
Parcel Number: 60420990900000000
Location: HCA MIDWEST, LOTS 1A & 1B---LOT 1A
Type of Work: ALTERATION COMMERCIAL
Occupancy Group: INSTITUTIONAL, INCAPACITATED
Description: RENOVATIONS TO PHARMACY IN EXISTING HOSPITAL

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Rejected

1. A License Tax application completed by the contractor must be submitted to the City of Lee's Summit, Codes Administration Department, and any applicable License Tax paid prior to issuing a building permit.

Action required: Comment is for informational purposes.

2. All plans submitted for review on or after April 1, 2019 shall be designed to the requirements of the 2018 International Building Code, 2018 International Mechanical Code, 2018 International Plumbing Code, 2018 International Fuel Gas Code, 2018 International Fire Code, 2017 National Electric Code and the ANSI A117.1-2017 as amended and adopted by the City of Lee's Summit

Action required: Update code references.

3. Only one copy of spec was submitted.

Action required: Provide additional spec book.

4. 2018 IMC 510.6.5 Makeup air. Makeup air shall be provided at a rate approximately equal to the rate that air is exhausted by the hazardous exhaust system. Makeup air intakes shall be located in accordance with Section 401.1.

Action required: Demonstrate how makeup air is accomplished at hazardous exhaust.

Fire Plan Review

Reviewed By: Joe Dir

Rejected

1. 2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. .A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

ACTION REQUIRED:(information purposes)

Have the fire alarm system contractor provide shop drawings of any modifications to be done to the fire alarm system.

2. 2018 IFC 407.3- Identification. Individual containers of hazardous materials, cartons or packages shall be marked or labeled in accordance with applicable federal regulations. Buildings, rooms and spaces containing hazardous materials shall be identified by hazard warning signs in accordance with Section 2703.5.

ACTION REQUIRED:(verified at inspection)

HD compounding and non HD compounding areas shall be labeled with appropriate hazardous materials labeling.

3. 2018 IFC 403.11.1.5 - Tenant identification. Each occupied tenant space provided with a secondary exit to the exterior or exit corridor shall be provided with tenant identification by business name and/or address. Letters and numbers shall be posted on the corridor side of the door, be plainly legible and shall contrast with their background.

ACTION REQUIRED:(verified at inspection)

All rooms shall be identified with room use, readable from the corridors.

4. 2018 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

ACTION REQUIRED:(information purposes)

Have the fire sprinkler system contractor provide shop drawings of any modification to be done to the fire sprinkler system.

5. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:(information purposes)

Testing of any modifications done to the fire alarm system will be required prior to the final occupancy inspection. Contact the fire department to schedule testing. (816)969-1300.

6. 2018 IFC 906.2- General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

ACTION REQUIRED:(verified at inspection)

Provide one 2A-10BC fire extinguisher for the pharmacy area if (not existing). Fire extinguisher to be mounted on a wall or in a extinguisher cabinet on a normal path of travel close to an exit.

7. Compuonding exhaust hoods

ACTION REQUIRED: provide information bout the exhaust hood systems for the compounding areas. Compounding areas shall meet the USP 795,797,800 specs. Provide manufacturers spec sheets on the exhaust systems.

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.