

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183200
Address: 1706 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Failed	Tuesday, June 18, 2019

Corrective Action Required:	
1 THE FOLLOWING AREAS ARE APPROVED	EXTERIOR SHEAR WALL NAILING: EAST WING 137,38,39,40,45,46; NOT APPROVED DUE TO EXCESSIVE OVER-DRIVING OF FASTENERS: WEST WING EXCLUDING SOUTH END ELEVATION; NORTH WALL (EAST END ALREADY TAPED)

Comments: